

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT WASH
STATE OF OREGON

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

MAR 30 1979 (Please type or print)

013572

State Well No. 3s/1w-1
State Permit No. _____

(1) OWNER: SALEM, OREGON

Name TOM RENNE
Address 5515 S.W. Dogwood Dr. S.E.
Lake Oswego 97034

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

CASING INSTALLED: Threaded Welded
6" Diam. from 0 ft. to 35 ft. Gage 250
4" Diam. from 0 ft. to 350 ft. Gage Liner

PERFORATIONS: Perforated? Yes No.
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" Air " " " " " "
Better test 25 gal./min. with 2.5 ft. drawdown after 1 hrs.
Artesian flow g.p.m. _____
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal _____ sacks
How was cement grout placed? FROM BOTTOM
CA (GROUT PUMP)
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:
County Washington Driller's well number _____
_____ 1/4 Section 1 T. 3S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.
Depth at which water was first found 135 ft.
Static level 135 ft. below land surface. Date 12/11
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 350 ft. Depth of completed well 350 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|----------------------|------|-----|-----|
| TOP, Soil | | | |
| BROWN CLAY | 0 | 2 | |
| DECOMPOSED BASALT | 2 | 20 | |
| GRAY BASALT | 20 | 35 | |
| DECOMPOSED BASALT | 35 | 75 | |
| GRAY BASALT | 75 | 105 | |
| BROKEN BASALT | 105 | 125 | |
| DECOMPOSED BASALT | 125 | 135 | 135 |
| BLACK BASALT | 135 | 250 | |
| BROKEN BASALT | 250 | 254 | |
| BLACK BASALT | 254 | 310 | |
| BLACK BASALT, QUARTZ | 310 | 316 | |
| | 316 | 350 | |

Work started 12/8 19 78 Completed 12/11 19 78
Date well drilling machine moved off of well 12/11 19 78

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] David Shover Date 3/7, 19 79
(Drilling Machine Operator)
Drilling Machine Operator's License No. 594

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Aqua-Tech Well Construction Inc.
(Person, firm or corporation) (Type or print)
Address 808 Delta Dr. N.E. Salem
[Signed] David Beal
(Water Well Contractor)
Contractor's License No. 696 Date 12/12, 19 79